

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 12:32 pm

PWS ID: UTAH21012 **Name:** REDMOND TOWN WATER SYSTEM

Legal Contact: REDMOND TOWN **Rating:** Approved
DAVID R ECKER **Rating Date:** 03/22/1983

Address: PO BOX 117 **Activity Status:** Active
REDMOND, UT 84652

Phone Number:

City Served (Area):

County: SEVIER COUNTY

System Type: Community **Last Inv Update:** 05/24/2011 **Avg Daily Prod:**
Activity Status Cd: Active **Last Snty Srv Dt:** 05/19/2008 **Total Dsgn Cap:**
Population: 850 **Surveyor:** ELDEN L OLSEN **Total Emerg Cap:**
Oper Period: 1/1 to 12/31

Gal/Day Gal/Min

Contacts

Contact Type	Name	Title	Phone Numbers		Email Address
			Office	Emergency	
AC	ECKER, DAVID R		435-529-3278	435-529-7346	redmondtown@altazip.com

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Residential	Unknown	0	303
			303 Total Svc Connections

Storage

Total Storage: 850,000 GAL **Number of Units:** 4 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matrl	Overflow Elev	Activity Status	Press'd
ST001	100 K #1 STORAGE	Ground	100,000 GAL	Concrete		A	NO
ST002	100 K #2 STORAGE	Ground	100,000 GAL	Concrete		A	NO
ST003	150 K STORAGE	Ground	150,000 GAL	Concrete		A	NO
ST005	500 K STORAGE	Ground	500,000 GAL	Concrete		A	NO

Treatment Plants

No.	Plant Name	Approved Design Capacity (gal/day)	Activity Status	Treatment Process
TP002	1987 WELL CHLORINATOR		A	

Distribution System

Pump Type	Total Dyn Head ft H2O P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No				

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	REDMOND LAKE SPRING	Inactive	SP				Yes	GW	Other		
WS002	1987 WELL	Active	WL	6	400 GPM	400 GPM	Yes	GW	Permanent	1/1 to 12/31	
WS003	1976 WELL	Inactive	WL		125 GPM		Yes	GW	Permanent		

*Reports measured flow for wells, approved design capacity for all other sources.

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS004	1998 WELL	Active	WL		600 GPM		Yes	GW	Permanent	1/1 to 12/31	
WS005	CEMETERY WELL	Inactive	WL	12	300 GPM		Yes	GW	Other		

**Reports measured flow for wells, approved design capacity for all other sources.*